

KEMENTERIAN PEMBANGUNAN
NEGARA BRUNEI DARUSSALAM

BARANGAN YANG DILULUSKAN

Rujukan barangan yang diluluskan : (1864) KPN/ABCi/C/8.0

Tarikh dikeluarkan : 20th November 2012

Tarikh Mansuh : 20th November 2017

Dengan ini diakui bahawa, L.K.H (B) Sdn Bhd., Lot B, Kawasan Perindustrian Beribi 1, Jalan Gadong BE1118, Negara Brunei Darussalam telah mengikuti skim persijilan barangan Kementerian Pembangunan seperti keterangan di bawah ini :-

Skim Persijilan : Scheme 1
(refer certification procedures STD3/003
Issue No. 11, Revision 27th May 2008).

The use of these products subject to the user's
specific technical and contractual requirements.

Barangan yang diluluskan : "WIN COAT" FIRE RESISTANT COATED
DUCTWORK SYSTEM

Note :

- Tarikh mansuh sehingga 5 tahun, jika barangan tersebut didapati tidak mengikut "Standard and Quality" maka kebenaran akan ditarik balik.

Tajuk dan Nombor Piawai (spesikasi) yang berkenaan terhadap persijilan yang dikehendaki : ISO 9001 : 2008
Provision of Fire Protection Works for Mechanical Ventilation System

Issued by : Bureau Veritas Certification
Certificate No. : Q209225
Certification Validity : 02/09/2015

Certification Mark : BS.476 : Part 24 : 1987

Issued by : IFC Certification
Certificate No. : FSB 551
Certification Validity : 21/02/2016

[DR. HAJAH DAYANG SUZANA BINTI HAJI AWANG ADENAN]
b/p. Setiausaha Tetap (Teknikal & Professional)
Kementerian Pembangunan

Issued Date : 27/11/2012

APPENDIX 'A'

REF: APPROVAL OF "WINCOAT FIRE RESISTANT COATED DUCTWORK SYSTEM"

Brand Name : WINCOAT


Country of origin : Passive Fire Protection Sdn. Bhd
NO.27, Jalan Pengacara U1/48,
Temnsya Industrial Park,
40150 Shah Alam, Selangor Darul Ehsan,
Malaysia


Product / Model : As per the attached list

Quality Management System ISO :ISO 9001:2008 (Bureau Veritas)

Test certificate and report from Independent Testing Body : i) IFC Certification UK
ii) Malaysia Brand Certification Scheme
iii) Sirim QAS International Sdn. Bhd

The Building Services Section Department of Mechanical & Electrical Services (DME)/PWD have reviewed and no objection with the above products and suggested that the approval validity period of the above products to be five (5) years instead of based on the expiring date of the independent testing body. If there is any of the above approved product items be found not confirming to the standard and quality as submitted within the approval validity period above the approval will be withdraw.


Teo Seng Huat
Products & Registration
Building Services Section
Department of Mechanical & Electrical /PWD


DR. ROHANIYATI POKS DSP HJ. MOHD SALLEH
Head of Building Services Section
Department of Mechanical & Electrical /PWD