



اؤتوريتي كاو لن باغونن دان ايندوستري قمبيناان كمنترين قمباغونن

AUTORITI KAWALAN BANGUNAN DAN INDUSTRI PEMBINAAN
KEMENTERIAN PEMBANGUNAN

PERSIJILAN PRODUK BAHAN-BAHAN BINAAN

NAMA PEMBEKAL	: SISTEM INTEGRA SDN BHD
RUJUKAN PRODUK	: (0113)KPN/ABCi/C/8.2(a)
SKIM PERSIJILAN	: SKIM 2
PRODUK YANG DILULUSKAN	: LE GRAND SWITCHBOARD & DISTRIBUTION BOARD (XL3 SOLUTION)
TAJUK DAN NOMBOR PIAWAIAN	: ISO 9001:2015 Certificate No: 01100009182
NOTA	: Sila rujuk Lampiran B bagi senarai model yang diluluskan
LAMPIRAN DISERTAKAN	: <input checked="" type="checkbox"/> YA <input type="checkbox"/> TIDAK

Kebenaran ini adalah sah mulai 24 Disember 2018 hingga 02 November 2019.

Dalam tempoh ini, Jawatankuasa Persijilan Produk atau pemeriksa pihak ketiga (*3rd Party*) yang dilantik berhak untuk menjalankan pemeriksaan ke atas produk-produk berkenaan, bagi memastikan kualiti yang memuaskan dari masa ke semasa.

Jika kualiti produk didapati tidak menepati standard dan kualiti seperti yang dihadapkan dalam tempoh persijilan, maka kebenaran ini akan dibatalkan dan penggunaan produk tidak boleh diguna pakai dalam mana-mana projek Kerajaan.

Adalah diperingatkan bahawa kebenaran ini tertakluk kepada tarikh tempoh sahlaku pendaftaran syarikat pembekal di bawah Kementerian Pembangunan. Kebenaran ini akan ditarik balik serta merta jika didapati syarikat pembekal tidak mempunyai tempoh sahlaku pendaftaran pembekal.



Autoriti Kawalan Bangunan dan Industri Pembinaan
b/p Setiausaha Tetap
Kementerian Pembangunan

ABCi/SM

SYARIKATSISTEM INTEGRA SDN BHD

PRODUK LIST BAGI BARANGAN LE GRAND SWITCHBOARD & DISTRIBUTION BOARD (XLE SOLUTION)

No.	Name of product	Type of product	Product category	Model No	Certification of product issued by	Standard specification used	Certificate No.	Date Issue	Date of Expiry	Type Test Certificate issued by	Standard specification used	Certificate No.	Date of issue	Country of origin	Date of expiry
1	Le Grand XL3 400A	Three phases distribution board - Low voltage switchgear 415V (Un/Ue)- 500V (Uj) - 8kV (Uimp)- 50/60Hz - 280A (InA)- 25kA (Icc)	Power/Electrical : Low Voltage	XL3 400 - VX3 400A - HX3 250 Arr.74	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019, 11/12/2020, 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8), EN 61439-2: 2011	LOVAG-Certificate No. IT 12.066	10/11/2012	singapore	NA
		Three phases low voltage switchgear 415 V (Un/Ue)- 690 V (Uj)- 8 kV (Uimp)- 15kA (Icw)Bar A-50 Hz - 250 A (InA)	Power/Electrical : Low Voltage	XL3 400 - VX3 250 Arrangement 66	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011	LOVAG-Certificate No. IT 12.068	10/11/2012		
		Three phases low voltage switchgear 415 V (Un/Ue)- 690 V (Uj)- 8 kV (Uimp)- 15kA x I sec. (Icw)Bar A - 25 kA x 0,5 sec. (Icw)Bar B- 50 Hz - 400 A (InA)	Power/Electrical : Low Voltage	XL3 400 - VX3 400 Arrangement 67	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011	LOVAG-Certificate No. IT 12.069	10/11/2012		
		Three phases low voltage switchgear 415 V (Un/Ue)- 690 V (Uj) - 8 kV (Uimp)- 15kA (Icw)- 50 Hz - 250 A (InA)	Power/Electrical : Low Voltage	XL3 400 - VX3 250 Arrangement 68	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011	LOVAG-Certificate No. IT 12.070	10/11/2012		
		Three phases low voltage switchgear 415V(Un/Ue)-690 V (Uj)- 8 kV (Uimp)- 15kA XI sec.(L,w)25 kA XI sec.(L,w)- 50 Hz - 400 (InA)	Power/Electrical : Low Voltage	XL3 400 - VX3400 Arrangement 69	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011	LOVAG-Certificate No. IT 12.071	10/11/2012		
		Three phases low voltage switchgear 415V (Un/Ue)- 690V (Uj) - 6kV (Uimp) - 25kA (Icc)at 415V - 50Hz - 400A (InA)	Power/Electrical : Low Voltage	XL3 400 - VX3400 Arrangement 72	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8)- EN 61439-2:2011	LOVAG-Certificate No. IT 12.072	10/11/2012		

SYARIKATSISTEM INTEGRA SDN BHD

PRODUK LIST BAGI BARANGAN LE GRAND SWITCHBOARD & DISTRIBUTION BOARD (XLE SOLUTION)

No.	Name of product	Type of product	Product category	Model No	Certification of product issued by	Standard specification used	Certificate No.	Date Issue	Date of Expiry	Type Test Certificate issued by	Standard specification used	Certificate No.	Date of issue	Country of origin	Date of expiry
2	Le Grand XL3 800A	Three phases distribution board - Low voltage switchgear 415V (VolVe)- 690V (Vj) - 6kV (Vimp) 800A (InA)- 50kA (Icc)	Power/Electrical : Low Voltage	XL3800 - VX3800 Arrangement 73	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011	LOVAG-Certificate No. IT 12.067	10/11/2012	singapore	NA
		Three phases low voltage switchgear 415V (Un/Ue)- 690V (Uj) - 8kV (Uimp) - 50kA (Icw)- 50Hz- 800A (InA)	Power/Electrical : Low Voltage	XL3 800 - VX3800 Arrangement 71	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011	LOVAG-Certificate No. IT 12.074	10/11/2012		
		Three phases low voltage switchgear 415V (Un/Ue)- 690V (Uj) - 8kV (Ujimp) - 50kA (Icw)- 50Hz- 800A (InA)	Power/Electrical : Low Voltage	XL3 800 - VX3800 Arrangement 70	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011	LOVAG-Certificate No. IT 12.073	10/11/2012		
		Three phases low voltage switch gear 415V (Un/Ue)- 690V (Uj) - 4kV (Uimp) - 25kA(Iee)- 50Hz- 475A(InA)	Power/Electrical : Low Voltage	XL3800 - VX3800	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011	LOVAG-Certificate No. IT 12.075	10/11/2012		
3	Le Grand XL3 6300	Three phases low voltage switch gear 415V (Un/Ue)- 690V (Uj) - 8kV (Uimp) - 100kA(Iee)- 50Hz- 60HZ (In)4410	Power/Electrical : Low Voltage	XL3 6300 ARRANGEMENT T 80	TUV	ISO 9001, ISO 14001:2015, ISO 14001:2004 AND BS OHSAS 18001:2007	01 100 009182, 01 104 009182, 01 104 009182 AND 01 113 009182	11/10/2012 , 02/11/2018 , 12/12/2014	2/11/2019 , 11/12/2020 , 11/12/2017	ACAE	IEC 61439-2 Ed.2.0 (2011-8) EN 61439-2:2011.	Test certificate will follow as per stated in XL3 6300 PDF	NA		